



# JAMIA MILLIA ISLAMIA

Maulana Mohammad Ali Jauhar Marg, Jamia Nagar  
New Delhi-110025

## E-TENDER NOTICE

**BID DOCUMENT**  
**[Two bid system]**

**Re-NIT66/Equipment/DoEE/PICO/RO/JMI/2018**

**Date: 09.03.2018**

On behalf of The VICE CHANCELLOR, Jamia Millia Islamia (JMI), New Delhi, INDIA, online bids (Two-Bids System) are invited for supply of Equipment for Department of Electrical Engineering, JMI from reputed manufacturers or their authorized agents for the supply/installation/commissioning of the following item(s):

Sl. No	Name of the instrument	Enquiry Ref. No.	Qty.	EMD to be given in INR/equivalent Foreign currency
1	Distribution Network Model Development with IEDs, Ethernet Switch to Control, Measurement and Communication on IEC61850	<u>Re-NIT66/ Equipment/ DoEE/PICO/RO/JMI/2018</u>	01	NO EMD

**Minimum Warranty** : **One Year**  
**Website for Online bid Submission** : <https://eprocure.gov.in>  
**Last date & Time for online submission of bids** : **15.03.2018 at 13:00 Hrs**  
**Date/Time for opening of Technical bid** : **16.03.2018 at 15:00 Hrs**

**Technical Specifications are available at the bottom of the document.**

**KINDLY NOTE THAT ONLY ONLINE BID WILL BE CONSIDERED AGAINST THISTENDER. Further, requests for postponement will not be entertained.** Bids send by post/Fax/email bids shall be rejected straightway.

The Vice Chancellor, JMI reserves the right to accept/reject any or all tenders either in part or in full without assigning any reasons there for.

The Registrar

Note: All the bidders may kindly note that all future corrigendum/amendments will be published on JMI website and CPPP website only and no separate newspaper shall be released for the same. All the prospective bidders are therefore requested to visit the website regularly for any such changes/update.

## GENERAL CONDITIONS OF CONTRACT (GCC)

### **1. Definitions**

1.1 In this Contract, the following terms shall be interpreted as indicated:

- (i) "The Order" means the Purchase Order placed by the Purchaser including all the attachments and appendices thereto and all documents incorporated by reference therein;
- (ii) "The Contract Price" means the price payable to the Supplier under the Order for the full and proper performance of its contractual obligations;
- (iii) "The Goods" means all the equipment, machinery, and/or other materials, which the Supplier is required to supply to the Purchaser under the Contract;
- (iv) "Services" means services ancillary to the supply of the Goods, such as transportation and insurance, and any other incidental services, such as installation, commissioning, provision of technical assistance, training and other obligations of the Supplier covered under the Contract
- (v) "GCC" mean the General Conditions of Contract contained in this section.
- (vi) "SCC" means the Special Conditions of Contract.
- (vii) "The Purchaser" as specified in Special Conditions of Contract.
- (viii) "The Purchaser's country" is "India".
- (ix) "The Supplier" means the individual or firm supplying the Goods and Services under this Contract.
- (x) "Day" means calendar day.
- (xi) JMI/The Registrar/Purchaser/and SPO represent same entity.

### **2. Application**

2.1 These General Conditions shall apply to the extent that they are not superseded by provisions in other parts of the Contract.

### **3. Standards**

3.1 The Goods supplied under this Contract shall conform to the standards mentioned in the Technical Specifications. When no applicable standard is mentioned, the authoritative standard appropriate to the Goods' country of origin shall apply. Such standards shall be the latest issued, by the concerned institution.

### **4. Use of Contract Documents and Information**

4.1 The bidder shall not, without the Purchaser's prior written consent, disclose the Contract, or any provision thereof, or any specification, plan, drawing, pattern, sample or information furnished by or on behalf of the Purchaser in connection therewith, to any person other than a person employed by the Supplier in performance of the Contract. Disclosure to any such employed person shall be made in confidence and shall extend only so far, as may be necessary for purposes of such performance.

### **5. Patent Rights**

5.1 The bidder shall indemnify the Purchaser against all third-party claims of infringement of patent, trade mark or industrial design rights arising from use of the Goods or any part thereof in India.

### **6. Submission of the bids and EMD**

6.1 The procurement will be carried out through submission of online tenders only. No offer in physical form will be accepted and any such offer if received by JMI will be out rightly rejected. Tender documents can be downloaded from website of CPPP [www.eprocure.gov.in](http://www.eprocure.gov.in) and final bids (Technical and Financial) are to be uploaded on same website i.e. [www.eprocure.gov.in](http://www.eprocure.gov.in). The bidders should have a valid digital signature certificate (Class'II or Class'III) issued by any of the valid Certifying Authorities to participate in the online tender. The bids shall be uploaded in electronic form only on [www.eprocure.gov.in](http://www.eprocure.gov.in) website. Before submission of bids, the bidders are requested to kindly read the "Guidelines to bidders on CPPP's e-procurement module" available at the end of this tender document.

6.2 The original EMD amount in the form of Demand Draft/Pay shall be submitted to PICO, Jamia Millia Islamia, New Delhi by hand delivery/courier on or before the due date for submission of bids failing which the bid will be rejected. The reference no. of the Tender and superscribe the word "EMD" should be specifically mentioned on the top of the envelope.

## 7. Inspections and Tests

- 7.1 The Purchaser or its representative shall have the right to inspect and/or to test the Goods to confirm their conformity to the Contract specifications at no extra cost to the Purchaser.

## 8. Packing

- 8.1 The Supplier shall provide such packing of the Goods as is required to prevent their damage or deterioration during transit to their final destination as indicated in the Contract. The packing shall be sufficient to withstand, without limitation, rough handling during transit and exposure to extreme temperatures, salt and precipitation during transit and open storage. Packing case size and weights shall take into consideration, where appropriate, the remoteness of the Goods' final destination and the absence of heavy handling facilities at all points in transit.
- 8.2 The packing, marking and documentation within and outside the packages shall comply strictly with such special requirements as shall be provided for in the Contract including additional requirements, if any, specified in SCC and in any subsequent instructions ordered by the Purchaser.
- 8.3 Packing Instructions: Each package will be marked on three sides with proper paint/indelible ink, the following:
- (i) Item Nomenclature
  - (ii) Order/Contract No.
  - (iii) Country of Origin of Goods
  - (iv) Supplier's Name and
  - (v) Packing list reference number

## 9. Delivery and Documents

- 9.1 Delivery of the Goods shall be made by the Supplier in accordance with the terms specified by the Purchaser in the order within the period as indicated in the SCC. The details of shipping and/or other documents to be furnished by the supplier are specified in SCC.
- 9.2 Delivery of the goods should be made within a maximum of 30 Days from the date of placement of purchase order. Within 24 hours of shipment, the supplier shall notify the purchaser and the insurance company by cable/telex/fax/e mail the full details of the shipment including contract number, railway receipt number/ AWB etc and date, description of goods, quantity, name of the consignee, invoice etc. The supplier shall mail the following documents to the purchaser with a copy to the insurance company:
- (i) Three copies of the Supplier invoice showing contract number, goods' description, quantity, unit price, total amount;
  - (ii) Acknowledgment of receipt of goods from the consignee(s) by the transporter;
  - (iii) Insurance Certificate if applicable;
  - (iv) Manufacturer's/Supplier's warranty certificate;
  - (v) Inspection Certificate issued by the nominated inspection agency, if any, and the Supplier's factory inspection report; and
  - (vi) Certificate of Origin.
  - (vii) Two copies of the packing list identifying the contents of each package.
- 9.3 The above documents should be received by the Purchaser before arrival of the Goods (except where the Goods have been delivered directly to the Consignee with all documents) and, if not received, the Supplier will be responsible for any consequent expenses including demurrage charges.

## 10. Insurance

- 10.1 The Goods supplied under the Contract shall be fully insured in Indian Rupees against loss or damage incidental to manufacture or acquisition, transportation, storage and delivery.
- 10.2 For delivery of goods at the purchaser's premises, the insurance shall be obtained by the Supplier in an amount equal to 110% of the value of the goods from "warehouse to warehouse" (final destinations) on "All Risks" The insurance shall be valid for a period of not less than three months after installation and commissioning. **However, in case of orders placed on FOB/FCA basis, the purchaser shall arrange Insurance.**

## 11. Transportation

- 11.1 Where the bidder is required under the Contract to transport the Goods to a specified place of destination within India defined as Project site, transport to such destination in India including insurance, as shall be specified in the Contract, shall be arranged by the Supplier, and the related cost shall be included in the Contract Price.

## 12. Spare Parts

- 12.1 As specified in the SCC, the Supplier may be required to provide any or all of the following materials, notifications, and information pertaining to spare parts manufactured or distributed by the Supplier:
- (i) Such spare parts as the Purchaser may elect to purchase from the Supplier, provided this election shall not relieve the Supplier of any warranty obligations under the Contract;
- 12.2 Supplier shall carry sufficient inventories to assure ex-stock supply of consumable spares for the Goods, such as gaskets, plugs, washers, belts etc. Other spare parts and components shall be supplied as promptly as possible but in any case within six months of placement of order.
- 12.3 The incidental services also include:
- 12.4 Furnishing of one set of detailed operations & maintenance manual.

## 13. Warranty

- 13.1 The Supplier warrants that the Goods supplied under this Contract are new, unused, of the most recent or current models and those they incorporate all recent improvements in design and materials unless provided otherwise in the Contract. The Supplier further warrants that all Goods supplied under this Contract shall have no defect arising from manufacturing, design, materials or workmanship (except when the design and/or material is required by the Purchaser's Specifications) or from any act or omission of the Supplier, that may develop under normal use of the supplied Goods in the conditions prevailing in the country of final destination. **The warranty should be comprehensive and on site.**
- 13.2 This warranty shall remain valid for a period as mentioned on specification page after the Goods or any portion thereof as the case may be, have been delivered, installed & commissioned and accepted at the final destination indicated in the Contract.
- 13.3 Warranty period shall be as mentioned on specification page from date of successful installation of equipment. The Supplier shall, in addition, comply with the performance and/or consumption guarantees specified under the contract. If for reasons attributable to the Supplier, these guarantees are not attained in whole or in part, the Supplier's discretion shall apply making such changes, modifications, and/or additions to the goods or any part thereof as may be necessary in order to attain the contractual guarantees specified in the Contract at supplier own cost and expense and to carry out further performance tests. **The warranty should be comprehensive on site.**
- 13.4 If during warranty period any component or spare part is needed, the same should be supplied free of cost with same configuration or better configuration. All associated cost for replacement of spare parts shall be borne by the supplier including the cost of customs duty, customs clearance charges etc.
- 13.5 In case of complaint regarding repairing/replacement of equipment/instrument within warranty period, the supplier will provide repair/replacement immediately. In case of non-compliance/delay compliance, the supplier will be penalized with an amount mutually agreed upon and it would be deducted from bank guarantee.

## 14. Payment

- 14.1 Preference will be given to the supplier who supplies the goods against 100% payment after supply, Installation and commissioning of the equipment(s). Payment may be made through L/C.
- 14.2 Agency commission, if any shall be paid after satisfactory installation & commissioning of the goods.
- 14.3 Purchaser is not liable to pay any interest amount on EMD in any condition.
- 14.4 Payment of bill shall be processed after completion of supply of all goods as per order. Part payment/piecemeal payment of purchase order shall not be allowed.

## 15. Prices

- 15.1 Prices charged by the Supplier for Goods delivered and Services performed under the Contract shall not vary from the prices quoted by the Supplier in the bid.
- 15.2 Price will be quoted in both words and figures. In case of any difference, the prices quoted in words shall prevail.

## 16. Subcontracts

- 16.1 The Supplier shall notify the Purchaser in writing of all subcontracts awarded under this Contract if not already specified in the bid. Such notification, in his original bid or later, shall not relieve the Supplier from any liability or obligation under the Contract.
- 16.2 Sub-contract shall be only for bought-out items and sub-assemblies.

**17. Delays in the Supplier's Performance**

17.1 Since time is the essence of the contract, delivery of the Goods and performance of the Services shall be made by the Supplier in accordance with the time schedule specified by the Purchaser in the Contract.

**18. Penalty**

18.1 If the Supplier fails to deliver any or all of the Goods or to perform services within the period(s) specified in the Contract, the Purchaser shall, without prejudice to its other remedies under the Contract, deduct from the Contract Price, as penalty, a sum equivalent to 1% per week and the maximum deduction is 10% of the contract price. Such payment shall be deducted from the same bill or any other bill due to supplier from JMI

**19. Termination for Default**

19.1 The Purchaser may, without prejudice to any other remedy for breach of contract, by written notice of default sent to the Supplier, terminate the Contract in whole or part:

(i) If the Supplier fails to deliver any or all of the Goods within the period(s) specified in the order, or within any extension thereof granted by the Purchaser.

(ii) If the Supplier fails to perform any other obligation(s) under the Contract.

(ii) If the Supplier, in the judgment of the Purchaser has engaged in corrupt or fraudulent practices in competing for or in executing the Contract.

19.2 For the purpose of this Clause:

(i) "Corrupt practice" means the offering, giving, receiving or soliciting of gratification to influence the action of a public official(s) in the procurement process or in contract execution.

(ii) "Fraudulent practice" means a misrepresentation of facts in order to influence a procurement process or the execution of a contract to the detriment of the purchaser, and includes collusive practice among Bidders (prior to or after bid submission) designed to establish bid prices at artificial non-competitive levels and to deprive the purchaser of the benefits of free and open competition;"

**20. Force Majeure**

20.1 The Supplier shall not be liable for forfeiture of its performance security, liquidated damages or termination for default, if and to the extent that, it's delay in performance or other failure to perform its obligations under the Contract is the result of an event of Force Majeure.

20.2 For purposes of this Clause, "Force Majeure" means an event beyond the control of the Supplier and not involving the Supplier's fault or negligence and not foreseeable. Such events may include, but are not limited to, acts of the Purchaser either in its sovereign or contractual capacity, wars or revolutions, fires, floods, epidemics, quarantine restrictions, act of God and freight embargoes.

**21. Resolution of Disputes**

21.1 The Purchaser and the supplier shall make every effort to resolve amicably by direct informal negotiation any disagreement or dispute arising between them under or in connection with the Contract.

21.2 If, after thirty (30) days from the commencement of such informal negotiations, the Purchaser and the Supplier have been unable to resolve amicably a contractual dispute, either party may require that the dispute be referred for resolution to the formal mechanisms. These mechanisms may include, but are not limited to, conciliation mediated by a third party, adjudication in an agreed national or international forum, and national or international arbitration.

21.3 In case of Dispute or difference arising between the Purchaser and a domestic supplier relating to any matter arising out of or connected with this agreement, such disputes or difference shall be settled in accordance with the Indian Arbitration & Conciliation Act, 1996, the rules there under and any statutory modifications or re-enactments thereof shall apply to the arbitration proceedings. The dispute shall be referred to the Registrar JMI and if he is unable or unwilling to act, to the sole arbitration of some other person appointed by him willing to act as such Arbitrator. The award of the arbitrator so appointed shall be final, conclusive and binding on all parties to this order.

(i) In the case of a dispute between the purchaser and a Foreign Supplier, the dispute shall be settled by arbitration in accordance with provision of sub-clause (a) above. But if this is not acceptable to the supplier then the dispute shall be settled in accordance with provisions of UNCITRAL (United Nations Commission on International Trade Law) Arbitration Rules.

**22. Taxes and Duties**

22.1 Suppliers shall be entirely responsible for all taxes, duties, license fees, octroi, road permits, etc., incurred until delivery of the contracted Goods to the Purchaser. However, GST in respect of the transaction between the Purchaser and the Supplier shall be payable extra, if so stipulated in the order.

**23. Inspection and Tests:** Inspection and tests prior to shipment of Goods and at final acceptance are as follows:

23.1 After the goods are manufactured and assembled, inspection and testing of the goods shall be carried out at the supplier’s plant by the supplier, prior to shipment to check whether the goods are in conformity with the technical specifications attached to the purchase order. Manufacturer’s test certificate with data sheet shall be issued to this effect and submitted along with the delivery documents. The purchaser shall be present at the supplier’s premises during such inspection and testing by purchaser. The location where the inspection is required to be conducted should be clearly indicated. The supplier shall inform the purchaser about the site preparation, if any, needed for installation of the goods at the purchaser’s site at the time of submission of order acceptance.

23.2 The acceptance test will be conducted by the Purchaser, their consultant or other such person nominated by the Purchaser at its option after the equipment is installed at purchaser’s site in the presence of supplier’s representatives. The acceptance will involve trouble free operation and ascertaining conformity with the ordered specifications and quality. There shall not be any additional charges for carrying out acceptance test. No malfunction, partial or complete failure of any part of the equipment is expected to occur. The Supplier shall maintain necessary log in respect of the result of the test to establish to the entire satisfaction of the Purchaser, the successful completion of the test specified.

23.3 In the event of the ordered item failing to pass the acceptance test, a period not exceeding one week will be given to rectify the defects and clear the acceptance test, failing which the Purchaser reserve the right to get the equipment replaced by the Supplier at no extra cost to the Purchaser.

23.4 Successful conduct and conclusion of the acceptance test for the installed goods and equipment(s) shall also be the responsibility and at the cost of the Supplier.

**24. Manuals and Drawings**

24.1 Before the goods are taken over by the Purchaser, the Supplier shall supply operation and maintenance manuals. These shall be in such details as will enable the Purchaser to operate, maintain, adjust and repair all parts of the equipment as stated in the specifications.

24.2 The Manuals shall be in English in such form and numbers as stated in the contract.

24.3 Unless and otherwise agreed, the goods/ equipment shall not be considered to be completed for the purposes of taking over until such manuals and drawing have been supplied to the Purchaser.

**25. Applicable Law:** The place of jurisdiction would be New Delhi, INDIA.

**26. Notices:** For the purpose of all notices, the following shall be the address of the Purchaser and Supplier.

**I Purchaser:**

The Registrar  
JAMIA MILLIA ISLAMIA  
Maulana Mohammad Ali Jauhar Marg,  
Jamia Nagar New Delhi-110025  
+91-11-26981717

*ii Supplier:*

(To be filled in by the supplier)

.....  
.....  
.....

## INSTRUCTION TO BIDDERS (ITB)

### INTRODUCTION

#### 1. Eligible Bidders

- 1.1 This invitation for Bids is open to all manufacturers or their dealers specifically authorized by the manufacturers to quote on their behalf for this tender as per manufacturer's authorization form and Indian agents of foreign principals, if any who possess the qualifying requirements specified in this tender.
- 1.2 Bidders should not be associated, or have been associated in the past, directly or indirectly, with a firm or any of its affiliates which have been engaged by the Purchaser to provide consulting services for the preparation of the design, specifications, and other documents to be used for the procurement of the goods to be purchased under this Invitation of Bids.
- 1.3 If any agent submits bid on behalf of the Principal/OEM, the same agent shall not submit as bid on behalf of any other principal/OEM in the same tender for the same product.
- 1.4 In a bid, either the Indian Agent on behalf of the principal/OEM or principal/OEM itself can bid but both cannot bid simultaneously for the same item/product in the same bid.
- 1.5 The bidders may submit the proprietary certificate for the item(s) if applicable

#### 2. Cost of Bidding

- 2.1 The Bidder shall bear all costs associated with the preparation and submission of its bid, and "the Purchaser", will in no case be responsible or liable for these costs, regardless of the conduct or outcome of the bidding process.

### THE BIDDING DOCUMENTS

#### 3. Cost of Bid Document

- 3.1 As mentioned on first page.

#### 4. Contents of Bid Document

- 4.1 The Bidder is expected to examine all instructions, forms, terms (ITB/GCC/SCC etc.), and specifications in the bidding documents. Failure to furnish all information required by the bidding documents or submission of a bid not substantially responsive shall result in rejection of the bid.

#### 5. Amendment to Bid Document

- 5.1 The prospective bidders are **required** to keep a watch on the CPPP/JMI website w.r.t. any amendment to the tender document or to clarification to the queries raised by the bidders up to seven days prior to the opening of the tender. The Purchaser reserves the right to reject the bids if the bids are submitted without taking into account these amendments/clarifications. In order to allow prospective bidders reasonable time in which to take the amendment into account in preparing their bids, the Purchaser, at its discretion, may extend the deadline for the submission of bids.

### PREPARATION OF BIDS

#### 6. Documents Comprising the Bid

The bid is required to be uploaded its bids on the CPP portal in **two parts**. One part is the Techno-Commercial Unpriced Bid and the other part is the Financial/Price Bid.

- 6.1 The Techno-Commercial Unpriced Bid prepared by the Bidder shall include the following without indicating the price in the Bid Form.
  - (i) Scanned copy of Tender fees and EMD as specified in the invitation to Bids.
  - (ii) Service Support Details Form;
  - (iii) T&C Deviation Statement Form;
  - (iv) Technical Specification Compliance Form;
  - (v) Performance Statement Form;
  - (vi) Manufacturer's Authorization Form.
  - (vii) Documentary evidence establishing that the bidder is eligible to bid and is qualified to perform the contract if its bid is accepted as per qualification requirements/criteria.
  - (viii) Bid Form.

- (ix) The Comprehensive Annual Maintenance Contract (CAMC) terms & conditions detailing the exclusions, if any and the estimated life of the equipment offered.
- (x) If the demonstration of the goods/equipment is deemed essential as per the technical requirements then confirmation reflecting willingness to arrange demonstration of the equipment offered free of charge at JMI or any other location on a mutually agreeable date, prior to opening of priced bid to ascertain conformity with the tendered specifications.

6.2 The Financial/Price Bid shall comprise of the Techno Commercial Bid with price indicated in the bid form. Also, Price Schedule 'Part A' and 'Part B' given with tender to be uploaded after filling all relevant information like Rate, freight, insurance, custom duty etc. The Rate should be inclusive of all charges and no other charges shall be considered. The priced bid should be uploaded strictly as per the format available with the tender failing which the offer is liable for rejection (renaming or changing format of Price schedule sheet will not be accepted by system).

## 7. Bid Prices

7.1 The Bidder shall indicate the unit prices and total bid prices of the goods it proposes to supply under the order and enclose it with the priced bid.

7.2 Prices indicated shall be entered separately in the following manner (**For Indigenous Items**):

- (i) The price of the goods, quoted (ex-works, ex-factory, ex-showroom, ex-warehouse, or off-the-shelf, as applicable), including all duties and sales and other taxes already paid or payable
- (ii) **Taxes:** JMI is exempted from payment of Excise Duty under notification number 10/97 dated 01.03.1997 and Customs Duty under notification No.51/96 dated 23.07.1996. **Hence Excise Duty, if any, should be shown separately.** Please mention the applicable taxes (GST) clearly. We don't issue any 'Form C' or 'Form D'. However, being R&D Organization Concessional customs duty Forms can be issued. **No other charges except those mentioned clearly in the bid will be admissible.**
- (iii) Rates should be quoted F.O.R. at site at JMI, New Delhi inclusive of packing, forwarding, loading & unloading, shifting up to the site of installation at JMI, installation and commissioning charges etc. If ex-works prices are quoted then packing, forwarding, documentation, freight and insurance charges must be clearly mentioned separately and clearly. Vague terms like packing, forwarding, transportation etc. without mentioning the specific amount/percentage of these charges will not be accepted. Such offers shall be treated as incomplete and rejected. **Where there is no mention of packing, forwarding, freight, insurance charges, such offers shall be assumed as all inclusive of above charges.**

7.3 Prices indicated shall be entered separately in the following manner (**For Imported Items, quote the DDP price all inclusive of all charges as given below**):

- (i) **The price of the goods quoted shall be inclusive of export packing, forwarding, inland freight, airfreight, Insurance, custom clearance charges, customs duty, loading & unloading, delivery, shifting if required up to the site/laboratory at JMI, installation and commissioning, training and insurance from warehouse to warehouse (up to site of installation of JMI). And other local costs incidental to delivery of the goods up to the site of installation at JMI. However the JMI will provide Original Duty Exemption Certificate, copy of DSIR Registration certificate etc. if required by the vendor.**

7.4 Prices quoted by the bidder shall remain fixed during the entire period of contract and shall not be subject to variation on any account. A bid submitted with an adjustable price the bid will be treated as non - responsive and rejected.

## 8. Bid Currencies

8.1 Prices shall be quoted in Indian Rupees or in freely convertible foreign currency preferably in **USD (\$), Euro (€), Yen (¥), GBP (£), SGD & AUD** wherever possible for correct evaluation during comparison.

## 9. Documents Establishing Bidder's Eligibility and Qualifications

9.1 Pursuant to JMI, the bidder shall furnish, as part of the bid, documents establishing the bidders' eligibility to bid and qualification to perform the contract if the bid is accepted.

9.2 That the bidder meets the qualification criteria listed in Bid Document.



## **10. Documents Establishing Goods' Eligibility and Conformity to Bid Document**

The documentary evidence of the goods and services eligibility shall consist of a statement on the country of origin of the goods and services offered which shall be confirmed by a certificate of origin at the time of shipment.

10.1 Specifications are basic essence of the product. It must be ensured that the offers are strictly as per specifications. At the same time it must also be kept in mind that merely copying our specifications in the bid shall not make firms eligible for consideration. The documentary evidence of conformity of the goods and services to the Bid Document may be in the form of literature, drawings, data, and shall consist of:

- (i) A detailed description of the essential technical and performance characteristics of the goods as per specifications;
- (ii) A list giving full particulars, including available sources and current prices, of spare parts, special tools, etc., necessary for the proper and continuing functioning of the goods for a period of two years, following commencement of the use of the goods by the Purchaser; and
- (iii) An item-by-item commentary on the Purchaser's technical specifications demonstrating substantial responsiveness of the goods and services to those specifications or a statement of deviations and exceptions to the provisions of the technical specifications.

## **11. Period of Validity of Bids**

11.1 Bids shall remain valid for 90 days from the date of opening the bid prescribed by the Purchaser. A bid valid for a shorter period may be rejected by the Purchaser as non-responsive.

## **12. Format and Signing of Bid**

12.1.1 The Bidder shall upload the bids in two parts. One part shall contain Techno commercial un-priced bid and the other shall contain the priced bid.

12.2 All pages of the bid, except for un-amended printed literature, shall be initialed by the person or persons signing the bid.

12.3 Any interlineations, erasures or overwriting shall be valid only if the persons or persons signing the bid endorse them.

12.4 The Bidder shall furnish information on commissions or gratuities, if any paid or to be paid to agents relating to this Bid, and to contract execution if the Bidder is awarded the contract as per the bid form.

12.5 The bid once accepted and awarded the contract the bidder will be obliged to execute the contract for the delivery and commissioning of the product at JMI.

## **13. Modification and Withdrawal of Bids**

13.1 The Bidder may modify or withdraw its bid after the bid's submission; prior to the deadline prescribed for online submission of bids.

13.2 No bid may be modified subsequent to the deadline for online submission of bids.

13.3 No bid may be withdrawn in the interval between the deadline for online submission of bids and the expiration of the period of bid validity specified by the Bidder on the bid form. Withdrawal of a bid during this interval may result in the Bidder's forfeiture of its bid security.

## **OPENING AND EVALUATION OF BIDS**

### **17. Opening of Bids by the Purchaser**

17.1 The Purchaser will open all Techno Commercial Un-priced Bids, as per the schedule given in invitation to bids.

17.2 In the event of the specified date of Bid opening being declared a holiday for the Purchaser, the Bids shall be opened on the next working day.

17.3 The Financial/price bid of technically qualified bidders only will be opened at the date and time to be informed to the qualified bidders.

## 18. Clarification of Bids

18.1 To assist in the examination, evaluation and comparison of bids, the Purchaser may, at its discretion ask the bidder for any clarification(s) of its bid. The request for clarification and the response shall be in writing and no change in the price substance of the bid shall be sought, offered or permitted. However no post Bid clarifications at the initiative of the Bidder shall be entertained.

## 19. Preliminary Examination

19.1 The Purchaser will examine the bids to determine whether they are complete, whether required sureties have been furnished, whether the documents have been properly signed, and whether the bids are generally in order. Bid from suppliers, without proper Authorization from the manufacturers and from Indian agents without DGS&D Registration Certificate in case the items fall under the restricted list of the current EXIM/Foreign.

19.2 The Purchaser may waive any minor informality, non-conformity, or irregularity in a bid, which does not constitute a material deviation, provided such a waiver, does not prejudice or affect the relative ranking of any Bidder.

19.3 Prior to the detailed evaluation, the Purchaser will determine the substantial responsiveness of each bid to the Bid Document. For purposes of these Clauses, a substantially responsive bid is one, which conforms to all the terms and conditions of the Bid Document without material deviations.

19.4 On downloading from the web site, the language of standard clauses etc. mentioned in this 'Bid Document' should not be tampered with/ changed/modified in any manner whatsoever. If any such modification etc. is noticed the purchaser at any stage, the bid shall be rejected immediately and EMD shall stand forfeited.

## 20. Conversion to Single Currency

20.1 To facilitate evaluation and comparison, the Purchaser will convert all bid prices expressed in the amounts in various currencies in which the bid prices are payable to Indian Rupees at the selling exchange rate established by any bank in India as notified in the Newspapers/banks' website on the date of Price/Financial Bid opening.

## 21. Evaluation & Comparison of Bids

21.1 For the bids qualifying for the technical evaluation which have been found to be responsive the evaluation & comparison shall be made as under:

(i) **Indigenous Offers**

The final landed cost of purchase after all discounts, freight, forwarding, insurance (warehouse to warehouse), custom clearing charges taxes etc. shall be the basis of evaluation.

(ii) **Imported Offers**

The FOB/FCA/CIF/CIP price shall be the basis of evaluation (warehouse to ware house basis)

(iii) **Imported Vs. Indigenous Offers**

The final landed cost (ware house to ware house) of purchase taking into account, freight, forwarding, insurance, taxes etc. (CIF/CIP with customs duty, customs clearance charges, Bank/LC charges, transportation, delivery up to the site of installation at JMI, New Delhi as per available records with JMI for imported goods) shall be the basis of evaluation.

21.2 Conditional tenders/discounts etc. shall not be accepted. Rates quoted without attached conditions (viz. Discounts having linkages to quantity, payment terms etc.) will only be considered for evaluation purpose. Thus conditional discounted rates linked to quantities and prompt/advance payment etc, will be ignored for determining *inter-se* position. The Purchaser however reserves the right to use the discounted rate/rates considered workable and appropriate for counter offer to the successful tenderers.

## 22. Contacting the Purchaser

22.1 Any attempt by any Bidder to influence the Purchaser in its decisions on bid evaluation, bid comparison or contract award may result in rejection of the bid.

## 23. Purchaser's Right To Vary Quantities At Time Of Award

23.1 The Purchaser reserves the right at the time of Contract award to increase or decrease the quantity of goods and services originally specified in the Schedule of Requirements without any change in unit price or other terms and conditions.

**24. Purchaser's Right To Accept Any Bid and To Reject Any or All Bids**

24.1 The Purchaser reserves the right to accept or reject any bid, and to annul the bidding process and reject all bids at any time prior to award of Contract, without thereby incurring any liability to the affected Bidder or bidders or any obligation to inform the affected Bidder or bidders of the grounds for the Purchaser's action.

24.2 Evidence regarding credibility of stable performance and maintenance service capability must be provided. The purchaser reserves the right to make judgment on this score and reject bids that, in the purchaser's view, do not carry sufficient credibility for performance and/or service.

**25. Notification of Award**

25.1 Prior to expiry of the period of bid validity, the purchaser will notify the successful bidder in writing by Purchase Order.

25.2 Upon the successful Bidder's furnishing of performance security the purchaser will promptly notify each unsuccessful Bidder and will discharge its bid security.

**26. Order Acceptance**

26.1 The successful bidder should submit acceptance of the Purchase Order immediately but not later than 21 days in any case from the date of issue of the Purchase Order failing which it shall be presumed that the vendor is not interested and his bid security is liable to be forfeited

**27. Performance Security**

27.1 The successful Bidder shall furnish the performance security equivalent to 10% of the cost of equipment, in the form of Bank Guarantee from scheduled bank after installation/ commissioning of the equipment(s). which would remain valid for a period of 60 days beyond the date of completion of all obligations of the supplier including warranty obligation. EMD will be released of successful bidder after submission of Bank Guarantee. JMI shall forfeit Bank Guarantee in the event of breach of contract by the successful supplier.

27.2 The payment will be released on receipt of performance security as per 26.1 above,

**28. Buy Back Items**

28.1 If the goods are to be quoted on 'Buy Back' basis, then bidders must offer a separate buy back price for the old item. The Purchaser reserves the right to place the order with or without 'buy back' option. If required the condition of old buy back goods may be examined by the bidder before submission of its bid.

**29. Progress of Supply**

29.1 Supplier shall regularly intimate progress of supply, in writing, to the Purchaser as under:

(i) Quantity offered for inspection and date;

(ii) Quantity accepted/rejected by inspecting agency and date;

(iii) Quantity dispatched/delivered to consignees and date;

(iv) Incidental services have been satisfactorily completed with date;

(v) Number of rectifications/repairs/replacements effected/completed on receipt of any communication from consignee/Purchaser with date;

(vi) Date of completion of entire Contract including incidental services, if any; and

(vii) Date of receipt of entire payments under the Contract (In case of stage-wise inspection, details required may also be specified).

**30. Right to Use Defective Goods**

30.1 If after delivery, acceptance and installation and within the guarantee and warranty period, the operation or use of the goods proves to be unsatisfactory, the Purchaser shall have the right to continue to operate or use such goods until rectifications of defects, errors or omissions by repair or by partial or complete replacement is made without interfering with the Purchaser's operation.

**31. Supplier Integrity**

31.1 The Supplier is responsible for and obliged to conduct all contracted activities in accordance with the Contract using state of the art methods and economic principles and exercising all means available to achieve the performance specified in the contract.

**32. Training**

32.1 The Supplier is required to train designated Purchaser's technical and end user personnel to enable them to effectively operate the total equipment.

32.2 The training shall be initially carried out during installation & commissioning for operating and maintaining the system. The specific training on application shall also to be imparted by the supplier. The duration of such training need to be finalized with the end user of the equipment.

32.3 In case any supplier is not willing to impart such training, the bid shall be treated as non-responsive.

**BID FORM**

**To,**  
**The Vice Chancellor,**  
**JAMIA MILLIA ISLAMIA**  
**Maulana Mohammad Ali Jauhar Marg,**  
**Jamia Nagar, New Delhi-110025**

Dear sir,

Having examined the bidding document the receipt of which is hereby duly acknowledged, we the undersigned offer to supply and deliver \_\_\_\_\_(Description of Goods) in conformity with the said bidding documents for a sum or such other sums as may be ascertained from the bid.

We undertake if our bid is accepted, to deliver the goods in accordance with the delivery schedule specified.

If our bid is accepted we will obtain the guarantee of the bank as specified in SCC for the due performance of the contract, in the form prescribed.

We agree to abide by this bid for requisite period as fixed for bid opening as per the instructions to the bidders. Further it shall remain binding upon us and accepted at any time before the expiry of that period.

Until a formal contract is prepared and executed, this bid, together with your written acceptance thereof and your notification of award shall constitute a binding contract between us.

Commission and gratuities, if any, paid or to be paid by us to the agents relating to this bid, and to contract execution if we are awarded the contract, are listed below:

Name and address of agent	Amount in Rupees	Purpose of Commission
(if none, state "none")		

We understand that you are not bound to accept the lowest or any bid you may receive.

Dated this \_\_\_\_\_ day of \_\_\_\_\_ 20 \_\_\_\_\_

Signature \_\_\_\_\_  
In the capacity of \_\_\_\_\_

Duly authorized to sign the bid for and on behalf of \_\_\_\_\_

**MANUFACTURERS AUTHORIZATION FORM**

No.

Date: \_\_\_\_\_

Vice Chancellor  
JAMIA MILLIA ISLAMIA  
Maulana Mohammad Ali Jauhar Marg,  
Jamia Nagar, New Delhi-110025

Dear Sir:

We who are established and reputable manufacturers of having factories/works at (*address*) do hereby authorize M/s (*Name and address of Agent*) to submit a bid, negotiate and receive the order from you against your tender enquiry mentioned on front page.

No company or firm or individual other than M/s is authorized to bid, and conclude the contract in regard to tender.

We hereby extend our full guarantee and warranty as per Clause 10.2 (iv) of the General Conditions of Contract and Clause of the Special Conditions of Contract for the goods and services offered by the above firm.

Yours faithfully,

(Name)

(Name of manufacturers)

**Note:** This letter of authority should be on the **letterhead of the manufacturer** and should be signed by a person competent and having the power of attorney to bind the manufacturer. It should be included by the Bidder in its techno-commercial unpriced bid.

**Form of Performance Bank Guarantee/Bank Guarantee**

BG No.:..... Date.....

<b>From</b> <b>The Name of the Bank</b>	<b>To</b> <b>Jamia Millia Islamia</b> <b>New Delhi-India</b>
--	--

In consideration of the Jamia Millia Islamia, New Delhi (hereinafter called "The JMI") having offered to accept the terms and conditions of the proposed agreement between The JMI.....and..... (hereinafter called "the Contractor(s)" for the work..... (hereinafter called "the said agreement") having agreed to production of an irrevocable Bank guarantee for Rs..... (Rupees.....only) as a security/guarantee form the contractor(s) for compliance of his obligations in accordance with the terms and conditions in the said agreement.

1. We ..... (hereinafter referred to as the "Bank") hereby undertake to (Indicate the name of the Bank) Pay to the JMI an amount not exceeding Rs..... (Rupees..... only) on demand.
2. We... (indicate the name of the Bank) ..... Do hereby undertake to pay the amounts due and payable under this Guarantee without any demur, merely on a demand from the JMI stating that the amount claimed is required to meet the recoveries due or likely to be due from the said contractor(s). Any such demand made on the Bank shall be conclusive as regards the amount due and payable by the Bank under this Guarantee. However, our liability under this Guarantee shall be restricted to an amount not exceeding Rs..... (Rupees.....only).
3. We, The said Bank, further undertake to pay to the JMI any money so demanded notwithstanding any disputes raised by the contractor(s) in any suit or proceeding pending before any Court or Tribunal relating thereto, our liability under this present being absolute and unequivocal. The payment so made by us under this bond shall be a valid discharge of our liability for payment thereunder, and the contractor(s) shall have no claim against us for making such payment.
4. We(indicate the name of the Bank) ..... further agree that the Guarantee herein contained shall remain in full force and effect during the period that would be taken for the performance of the said agreement, and it shall continue to be enforceable till all the dues of the JMI under or by virtue of the said agreement have been fully paid, and its claims satisfied or discharged, as per the terms and conditions of the said agreement have been fully and properly carried out by the said contractor(s), and accordingly discharges this guarantee.
5. We.....(Name of the bank)..... further agree with the JMI that the JMI shall have the fullest liberty without our consent, and without effecting in any manner our obligations hereunder, to vary any of the terms and conditions of the said agreement

or to extend time of performance by the said contractor(s) from time to time or to postpone for any time or from time to time any of the powers exercisable by the JMI against the said contractor(s), and to forbear or enforce any of the terms and conditions relating to the said agreement, and we shall not be relieved from our liability by reason of any such variation or extension being granted to the said not be relieved from our liability by reason of any such variation or extension being granted to the said contractor(s) or for any forbearance, act of omission on the part of the JMI or any indulgence by the JMI to the said contractor(s) or by any such matter or thing whatsoever which under the law relating to sureties would, but for this provision, have effect of so relieving us.

6. This Guarantee will not be discharged due to the change in the constitution of the Bank or the contractor(s).
7. We .....(Name of the bank)..... lastly under take not to revoke the Guarantee except with the previous consent of the JMI in writing. This bank Guarantee on the Bank or its successors or permitted assigns.
8. We.....(Indicate the name of the Bank)..... lastly undertake not to revoke this Guarantee except with (indicate the name of the Bank) the previous consent of the JMI extended on demand by the JMI. Notwithstanding anything mentioned above, our liability against this Guarantee is restricted to Rs.....(Rupees.....only), and unless a claim/demand is made on the bank in writing on or before .....all your rights under the Guarantee will be forfeited and we shall be relieved and discharged from all liabilities thereunder.

Authorized Signatories of the Bank with name and Seal

Name of the Officer:

Designation:

Code if any:

Date:

Place

## TECHNICAL COMPLIANCE STATEMENT FORM

An item-by-item commentary on the Purchaser's Technical Specifications demonstrating substantial responsiveness of the goods and services to those specifications or a statement of deviations and exceptions to the provisions of the Technical Specifications.

ITEM NAME			
S. No.	Tender Specifications	Bidder's Specifications	Remarks/Deviation If any

(Technical literature/brochures/manuals should be attached along with this format)

**Please note:**

1. Compliance/Deviation statement comparing the specifications of the quoted model to the required specifications. This statement should also give the page number(s) of the technical literature where the relevant specification is mentioned.
2. Bids must have supporting documents ( technical literature or copies of relevant pages from the service manual or factory test data) for all the points noted above, failure regarding which may result in rejection of bid.

### QUALIFICATION REQUIREMENTS

1. The Bidder should be a manufacturer or their dealer specifically authorized by the manufacturer to quote on their behalf for this tender as per manufacturer authorization form and Indian agents of foreign principals, if any who must have designed, manufactured, tested and supplied the equipment(s) similar to the type specified in the "Technical Specification". Such equipments must be of the most recent series/models incorporating the latest improvements in design. The models should be in successful operation for at least one year as on date of Bid Opening in India and is engaged in R&D activities.
2. The Indian Agents of foreign manufacturers/ suppliers quoting directly on behalf of their principals for items appearing in the restricted list of the current Foreign Trade Policy must be registered with DGS&D. One Indian Agent cannot represent two different foreign principals for the same item in one tender.
3. The bidder should have executed at least one similar order successfully during the preceding three financial years. The details should be incorporated in the performance statement form along with documentary evidence.
4. Details of service support facilities that would be provided after the warranty period should be submitted in the Service Support Details Form.
5. That, in the case of a Bidder not doing business in India, the Bidder is/or will be (if successful) represented by an Agent in India who shall be equipped and able to carry out the Supplier's maintenance, repairs and spare parts, stocking obligations prescribed by the conditions of the contract.
6. That the Bidder will assume total responsibility for the fault-free operation of equipment, application software, if any, and maintenance during the warranty period and provide necessary maintenance services for five years after end of warranty period if required.
7. Bidders who meet the criteria given above are subject to be disqualified, if they have made untrue or false representation in the forms, statements and attachments submitted in proof of the qualification requirements or have a record of poor performance, not properly completing the contract, inordinate delays in completion or financial failure, etc.
8. Other things being equal, preference shall be given to firms who or his principal have supplied and installed similar system at any CSIR/ ICAR/ ICMR/DAE/ DRDO/ DST/DBT/other Govt. or autonomous research Labs in India.
9. ***Any additional bid participation criteria / eligibility conditions etc. mentioned in the Technical Specifications sheet will also form part of the Qualification Requirements along with those mentioned in this chapter.***

**The Registrar**



# **Price Bid Format**

**(To be uploaded only in Financial Cover separately)**

**PRICE SCHEDULE 'A'**

**PRICE SCHEDULE FOR DOMESTIC GOODS OR GOODS OF FOREIGN ORIGIN TO BE SUPPLIED IN INDIAN CURRENCY**

1	2	3	4	5							6
Item Sl. No.	Brief Description of Goods (with make & model)	Country of origin	Quantity (Nos)	Price per unit (Rs.)							Total price (at consignee site) basis (Rs.)
				Ex-factory/Ex-warehouse/Ex-showroom/Off-the shelf	Excise Duty(if any) [%age & value]	Sales Tax/ GST (if any)[%age & value]	Transportation , loading/ unloading and incidental costs till consignee's site	Insurance charges for a period including 3 months beyond the date of delivery	Incidental services (including installation & commissioning, supervision, demonstration and training) at the consignee's site	Unit price (at consignee basis	
				(a)	(b)	(c)	(d)	(e)	(f)	(g) =a+b+c+d+e+f	4 x 5 (g)
1											

Total Tender price in Rupees: \_\_\_\_\_

In words: \_\_\_\_\_

Note: -

1. If there is a discrepancy between the unit price and total price THE UNIT PRICE shall prevail.
2. The charges for Annual CMC after warranty shall be quoted separately as per Section-XI – Price Schedule C

Name: \_\_\_\_\_

Business Address \_\_\_\_\_

Signature of Tenderer \_\_\_\_\_

Seal of Tenderer \_\_\_\_\_

Place: \_\_\_\_\_

Date: \_\_\_\_\_

**PRICE SCHEDULE**

**PRICE SCHEDULE FOR GOODS TO BE IMPORTED FROM ABROAD IN FOREIGN CURRENCY**

1	2	3	4	5												
Item Sl. No.	Brief description of goods (with make & model)	Country of origin	Qty (Nos.)	Gross price at sea/air port of Lading (inclusive of agency Commission)	FOB at port of Lading (inclusive of agency Commission)	Amount and percentage of Agency Commission **	Net FOB excluding Agency Commission (a-b)	Insurance & Freight	Net CIP by Air/Sea at the port of entry (c+d)	Custom Duty amount as % of Net CIP (amount with CDEC as applicable) **	Custom Clearance & Handling charges **	Loading/ Unloading, inland transportation, insurance & incidental costs till consignee's site **	Installation commissioning, supervision. Demonstration & training at the consignee's site **	Unit price on DDP basis at consignee's site		
				(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	In foreign currency	In Indian rupees		
															=(e)	=(b+f+g+h+i)

\*\* To be quoted in Indian Currency

Total price at Consignee's site  
(A) In Foreign currency : column (4 x e) \_\_\_\_\_ (In figures and words) plus

\*\* (B) In Indian Rupees : column 4 x (b+f+g+h+i) Rs. \_\_\_\_\_ (In figures and words)

Note:-

- The tendered will be fully responsible for the safe arrival of the goods at the consignee site in good condition as per terms of contract.
- The bidder break up of price under various columns is for comparison of price up to delivery of goods at consignee's site for tender evaluation.
- The quoted price should be supported with original proforma invoice. The proforma invoice should indicate the percentage of agency commission included in the FOB prices. Indian Agent to be paid in Indian currency.
- All the components of the DDP price will be paid by the tenderer. The purchaser will make the payment of DDP price after receipt of goods at consignee's site in good condition as per payment terms in the contract. The purchaser can place the order on CIP or DDP basis.
- The price quoted in foreign currency in column (e) shall be converted in Rupees at the selling rate of exchange applicable on the date of tender opening. The customs duty amount so worked out as percentage of net CIP value in rupees will be taken for evaluation and comparison of tenders.
- The charges for Annual CMC after warranty shall be quoted separately as per price schedule 'B'.

Name: \_\_\_\_\_  
 Business Address \_\_\_\_\_  
 Signature of Tenderer \_\_\_\_\_  
 Seal of Tenderer \_\_\_\_\_

Place: \_\_\_\_\_  
 Date: \_\_\_\_\_

**PRICE SCHEDULE 'B'**

**PRICE SCHEDULE FOR COMPREHENSIVE MAINTENANCE CONTRACT AFTER WARRANTY PERIOD**

1	2	3	4					5
Item Sl. No.	Brief Description of the Goods	Quantity (Nos.)	Comprehensive Maintenance Contract Cost for each Unit year wise*.					Total Comprehensive Maintenance Contract Cost for 5 (or as specified) Years [3 x (4a+4b+4c+4d+4e)]
			1 <sup>st</sup>	2 <sup>nd</sup>	3 <sup>rd</sup>	4 <sup>th</sup>	5 <sup>th</sup>	
			A	B	C	D	e	

\* After completion of warranty period

**Note: -**

1. The cost of Comprehensive Maintenance Contract (CMC) which includes preventive maintenance including testing & calibration as per technical/service/operational manual and labour, after satisfactory completion of warranty period may be quoted for next 5 (or as specified) years on yearly basis for complete equipment.
2. The cost of CMC may be quoted along with taxes applicable on the date of Tender opening. The taxes to be paid extra, to be specifically stated. In the absence of any such stipulation the price will be taken inclusive of such taxes and no claim for the same will be entertained later.
3. Cost of CMC may be added for ranking/evaluation purpose.
4. The uptime warranty will be 98% on 24 (hrs) x 7 (days) x 365 (days) basis.
5. The stipulation in technical specification will supersede above provision.
6. The supplier shall keep sufficient stock of spares required during comprehensive maintenance contract period. In case the spares are required to be imported, it would be the responsibility of the supplier to import and get them custom cleared and pay all necessary duties.

Place: \_\_\_\_\_

Date: \_\_\_\_\_

Name: \_\_\_\_\_

Business Address \_\_\_\_\_

Signature of Tenderer \_\_\_\_\_

Seal of Tenderer \_\_\_\_\_

# Guidelines to bidders on CPPP e-Procurement Module

## **1. Procedure for Registration by the Bidder**

- 1.1. Bidders are required to enroll on the e-Procurement module of the Central Public Procurement Portal (URL: <https://eprocure.gov.in/eprocure/app>) by clicking on the link "Click here to Enroll" on the CPP Portal.
- 1.2. As part of the enrolment process, the bidders will be required to choose a unique username and assign a password for their accounts.
- 1.3. Bidders are advised to register their valid email address and mobile numbers as part of the registration process. These would be used for any communication from the CPP Portal.
- 1.4. Upon enrolment, the bidders will be required to register their valid Digital Signature Certificate (Class II or Class III Certificates with signing key usage) issued by any Certifying Authority recognized by CCA India (e.g. Sify / TCS / nCode / eMudhra etc.), with their profile.
- 1.5. Only one valid DSC should be registered by a bidder. Please note that the bidders are responsible to ensure that they do not lend their DSC's to others which may lead to misuse.
- 1.6. Bidder then logs in to the site through the secured log-in by entering their user ID / password and the password of the DSC / e-Token.

## **2. Searching for Tender Documents**

- 2.1. There are various search options built in the CPP Portal, to facilitate bidders to search active tenders by several parameters. These parameters could include Tender ID, organization name, location, date, value, etc. There is also an option of advanced search for tenders, wherein the bidders may combine a number of search parameters such as organization name, form of contract, location, date, other keywords etc. to search for a tender published on the CPP Portal.
- 2.2. Once the bidders have selected the tenders they are interested in, they may download the required documents / tender schedules. These tenders can be moved to the respective 'My Tenders' folder. This would enable the CPP Portal to intimate the bidders through SMS / e-mail in case there is any corrigendum issued to the tender document.
- 2.3. The bidder should make a note of the unique Tender ID assigned to each tender, in case they want to obtain any clarification / help from the Helpdesk.

## **3. Procedure for preparation and submission of bids**

- 3.1. The documents should be page numbered and contain the list of contents with page numbers. The deficiency in documentation may result in the rejection of the Bid.
- 3.2. Bidder should take into account any corrigendum published (if any) on the tender document before submitting their bids.
- 3.3. The documents should be page numbered and contain the list of contents with page numbers. The deficiency in documentation may result in the rejection of the Bid.
- 3.4. Bidder should take into account any corrigendum published (if any) on the tender document before submitting their bids.
- 3.5. Bidders are advised to go through the Tender advertisement and the Tender document carefully to understand the documents required to be submitted as part of the bid. Please note the number of covers in which the bid documents have to be submitted, the number of documents - including the names and content of each of the document that need to be submitted. Any deviations from these may lead to rejection of the bid.
- 3.6. Bidder, in advance, should get ready the bid documents to be submitted as indicated in the tender document / schedule and generally, they can be in PDF formats. Bid documents may be scanned with 100 dpi.
- 3.7. To avoid the time and effort required in uploading the same set of standard documents which are required to be submitted as a part of every bid, a provision of uploading such standard documents (e.g. PAN card copy, annual reports, auditor certificates etc.) has been provided to the bidders. Bidders can use "My Space" area available to them to upload such documents. These documents may be directly submitted from the "My Space" area while submitting a bid, and need not be uploaded again and again. This will lead to a reduction in the time required for bid submission process.

3.8. As part of the bid, bidder should provide all the documents as follows:-

- Bidder should log into the site well in advance for bid submission so that he/she upload the bid in time i.e. on or before the bid submission time. Bidder will be responsible for any delay due to other issues.
- The bidder has to digitally sign and upload the required bid documents one by one as indicated in the tender document.
- The serve time (which is displayed on the bidders' dashboard) will be considered as the standard time for referencing the deadlines for submission of the bids by the bidders, opening of bids etc. The bidders should follow this time during bid submission.
- All the documents being submitted by the bidders would be encrypted to ensure the secrecy of the data. The data entered cannot be viewed by unauthorized persons until the time of bid opening. The confidentiality of the bids is maintained using the secured Socket Layer 128 bit encryption technology. Data storage encryption of sensitive fields is done.
- The uploaded tender documents become readable only after the tender opening by the authorized bid openers.
- Upon the successful and timely submission of bids, the portal will give a successful bid submission message & a bid summary will be displayed with the bid no. and the date & time of submission of the bid with all other relevant details.
- The bid summary has to be printed and kept as an acknowledgement of the submission of the bid. This acknowledgement may be used as an entry pass for any bid opening meetings

## **4. Assistance to Bidders**

Any queries relating to the NIT document and the terms and conditions contained therein should be addressed to the Assistant Registrar PICO, JMI

Any queries relating to the process of online bid submission or queries relating to CPP Portal in general may be directed to the 24x7 CPP Portal Helpdesk. For any technical related queries please call the Helpdesk. The 24 x 7 Help Desk Number 0120-4200462, 0120-4001002, 0120-4001005 and E-Mail : support-eproc[at]nic[dot]in

In Office Hour Only: +91 8804377070, 011-26982759

## Technical Bid


Sr. No.	Items/ Descriptions	Quantity	Compliance (Yes/No)
1	Numerical bay control unit with following Functions: control, monitoring, measurement, communication on IEC61850. Bay control functions including data collection functionality from process level MU for analog data as per IEC61850-9-2LE and control & monitoring data from SCU on GOOSE as per IEC81850-8-1.	1	
2	<ul style="list-style-type: none"> <li>● Numerical line distance protection relay with following Functions: include a directional back up Inverse Definite Minimum Time (IDMT) earth fault relay with normal inverse characteristics as per IEC 60255-3 as a built in feature</li> <li>● For numerical relays, the scope shall include the following:               <ul style="list-style-type: none"> <li>a) Necessary software and hardware to up/down load the data to/from the relay from/to the personal computer installed in the substation. However, the supply of PC is not covered under this scope.</li> <li>b) The relay shall have suitable communication facility for connectivity to SCADA (IEC61850-8-1) and to process bus (IEC61850-9-2LE).</li> </ul> </li> </ul>	1	
3	Station level Ethernet switch: The Ethernet Fast Switches shall be compliant to IEC 61850 and support time synchronization as per SNTP and PTP (IEEE1588 power profile). These Switches shall be suitable for the substation environment and shall conform to type tests as per IEC 61850-3. Ethernet switch shall be of 19" rack mounting type, dual power supply, 6 x FO port (100 Mbps, multimode, 1300nm, ST), 10 x copper port (10/100 Mbps, RJ45). Operating temperature range: -40 to +85 deg C.	1	

4	FO patch cable 10 meter.	1	
5	CAT 5 front communication cable 10 meter	1	
6	PCM600 software for Relay configuration and parameterization.	-	
7	Warranty	-	

**Research Objectives to be achieved with this model:-**

- To test horizontal communication testing (GOOSE).
- To test vertical communication testing (SVM Reports).
- To send Analog/Binary data to remote SCADA.
- To demonstrate breaker opening/closing through station HMI.
- To test interoperability with other equipments.
- To generate report/data logging on events. Installation, testing, commissioning and training to be done at Jamia Millia Islamia , New Delhi institutional Laboratory

**The Experimental Lab set-up to be done:-**



**All the equipments supplied should support the type of Merging Unit and Omicron Kit available in Jamia Lab:-**

**Merging Unit-** (TRDPRT) Analog merging unit with IEC 61850 ED2 & PRP protocol, 10DI, 6DO, 4current & 4 voltage channel, Self mount and power supply through AC adapter, Manufactured by VIZIMAX and supplied by SCOPE T&M Pvt. Ltd

**Omicron Kit-** Omicron CMC 256-6 kit with 4 x 300 V outputs, 6 x 12.5 A / 3 x 25 A outputs, 6 x low level outputs (rear side), 2 x counter inputs (rear side), dc supply (0 ... 264 V), 4 x binary outputs, dc measuring inputs, 10 x binary inputs /, Analog measurement inputs .

## General requirements of RELAYS

- All relays shall conform to the requirements of IS: 3231/IEC-60255/IEC 61000 or other applicable standards. Relays shall be suitable for flush or semi-flush mounting on the front with connections from the rear.
- All protective relays shall be of numerical type and communication protocol shall be as per IEC 61850 for station bus as well as process bus application. Protective relays shall also fulfill the requirements specified for Protection IEDs
- All protective relays shall be in draw out or plug-in type/modular cases with proper testing facilities. Necessary test plugs/test handles shall be supplied loose and shall be included in contractor's scope of supply.
- All AC operated relays shall be suitable for operation at 50 Hz. AC Voltage operated relays shall be suitable for 110 Volts VT secondary and current operated relays for 1 amp CT secondary. All DC operated relays and timers shall be designed for the DC voltage specified, and shall operate satisfactorily between 80% and 110% of rated voltage. Voltage operated relays shall have adequate thermal capacity for continuous operation.
- The protective relays shall be suitable for efficient and reliable operation of the protection scheme described in the specification.
- The setting ranges of the relays offered, if different from the ones specified shall also be acceptable if they meet the functional requirements.
- All relays and their drawings shall have phase indications as R-Red, Y-yellow, B-blue
- For numerical relays, the scope shall include the following:
  - a) Necessary software and hardware to up/down load the data to/from the relay from/to the personal computer installed in the substation. However, the supply of PC is not covered under this scope.
  - b) The relay shall have suitable communication facility for connectivity to SCADA (IEC61850-8-1) and to process bus (IEC61850-9-2LE).

### Distance Protection relay:

- shall have continuous self monitoring and diagnostic feature
- shall be non-switched type with separate measurements for all phase to phase and phase to ground faults
- shall have stepped time-distance characteristics and independent four forward zones and one reverse/offset zone
- shall have mho or quadrilateral or other suitably shaped characteristics for all zones.
- shall have following maximum operating time (including trip relay time, if any) under given set of conditions and with CVT being used on line (with all filters included)
- The relay shall have an adjustable characteristics angle setting range of 30-85 degree or shall have independent resistance(R) and reactance (X) setting.
- shall have two independent continuously variable time setting range of 0-3 seconds for zone-2 and 0-5 seconds for zone-3/reverse zone.
- shall have resetting time of less than 55 milli-seconds (including the resetting time of trip relays)
- shall have variable residual compensation for each zone
- shall have memory techniques with defined characteristics in all three phases to ensure correct operation during close-up 3 phase faults and other adverse conditions and shall operate instantaneously when circuit breaker is closed to zero-volt 3 phase fault
- shall have weak end in-feed feature



- shall be suitable for single & three phase tripping
- shall have a continuous current rating of two times of rated current. The voltage circuit shall be capable of operation at 1.2 times rated voltage. The relay shall also be capable of carrying a high short time current of 70 times rated current without damage for a period of 1 sec.
- shall be provided with necessary self reset type trip duty contacts for completion of the scheme (Minimum number of these trip duty contacts shall be four per phase) either through built in or through separate high speed trip relays. Making capacity of these trip contacts
- shall be 30 amp for 0.2 seconds with an inductive load of L/R > 10 milli seconds. If separate high speed trip relays are used, the operating time of the same shall not be more than 10 milliseconds
- shall be suitable for use in permissive under reach/ over reach/ blocking communication mode
- shall have suitable number of potential free contacts for Carrier aided Tripping, Auto reclosing, CB failure, Disturbance/Fault recorder & Data acquisition system
- include power swing blocking and out-of-step protection which shall
  - have suitable setting range to encircle the distance protection described above
  - block tripping of distance function zones during power swing conditions
  - release blocking in the event of actual fault
  - release tripping on detection of out-of-step power swing condition
  - include fuse failure protection which shall monitor all the three fuses of
- C.V.T. and associated cable against open circuit inhibit trip circuits on operation and initiate annunciation have an operating time less than 7 milliseconds remain inoperative for system earth faults
- include a directional back up Inverse Definite Minimum Time (IDMT) earth fault relay with normal inverse characteristics as per IEC 60255-3 as a built in feature
- Must have a current reversal guard feature.
- Shall have Stub protection function with current setting minimum range of 1 to 3 pu with definite time delay setting minimum range of 0 to 100msec.
- have feature of load encroachment blinder to safeguard the protection trip during heavy line loading condition.

**Shall be with Back-up Directional Over Current and Earth fault protection scheme**

- shall have three over current and one earth fault element(s) which shall be either independent or composite unit(s)
- shall include necessary VT fuse failure relays for alarm purposes
- over current elements shall
  - have IDMT characteristic (normal inverse as per IEC)
  - have a variable setting range of 50-200% of rated current
  - have a characteristic angle of 30/45 degree lead
  - include hand reset flag indicators or LEDs
- earth fault element shall
  - have IDMT characteristic (normal inverse as per IEC)
  - have a variable setting range of 20-80% of rated current
  - have a characteristic angle of 45/60 degree lag
  - include hand reset flag indicators or LEDs
  - include necessary separate interposing voltage transformers or have internal feature in the relay for open delta voltage to the relay
- **LINE OVER VOLTAGE PROTECTION RELAY** shall
  - monitor all three phases
  - have two independent stages

- have an adjustable setting range of 100-170% of rated voltage with a setting least count of 0.1V (Secondary volts) and an adjustable time delay range of 1 to 60 seconds for the first stage.
- have an adjustable setting range of 100-170% of rated voltage with a time delay of 100-200 mill seconds for the second stage.
- be tuned to power frequency provided with separate operation indicators (flag target) and signal for each stage relays with phase indication for event logging.
- have a drop-off to pick-up ratio greater than 97%

## Bay control Unit

Bay control functions including data collection functionality from process level MU for analog data as per IEC61850-9-2LE and control & monitoring data from SCU on GOOSE as per IEC61850-8-1.

### 1. Overview

#### Functions

- Control mode selection
- Select-before-execute principle
- Command supervision:
- Interlocking and blocking
- Double command
- Synchrocheck, voltage selection
- Run Time Command cancellation
- Transformer tap changer control (Raise and lower of tap ) (for power transformer bays only)
- Operation counters for circuit breakers and pumps
- Hydraulic pump/ Air compressor runtime supervision
- Operating pressure supervision through digital contacts only
- Breaker position indication per phase
- Alarm annunciation
- Measurement display
- Local HMI
- Interface to the station HMI
- Data storage for at least 200 events
- Interface to process level

### 2. Control mode selection

#### Bay level Operation:

As soon as the operator receives the operation access at bay level the operation is normally performed via bay control IED. During normal operation bay control unit allows the safe operation of all switching devices via the bay control IED.

#### EMERGENCY Operation

It shall be possible to close or open the selected Circuit Breaker with ON or OFF push buttons / control switch even during the outage of bay IED.

#### REMOTE mode

Control authority in this mode is given to a higher level (Remote Control Centre) and the installation can be controlled only remotely. Control operation from lower levels shall not be possible in this operating mode.

### 3. Synchronism and energizing check

The synchronism and energizing check functions shall be bay-oriented and distributed to the bay control and/or protection devices. These features are:

- Settable voltage, phase angle, and frequency difference.
- Energizing for dead line - live bus, live line - dead bus or dead line dead bus with no synchro-check function.
- Synchronising between live line and live bus with synchro-check function

### Voltage selection

The voltages relevant for the Synchro check functions are dependent on the station topology, i.e. on the positions of the circuit breakers and/or the isolators. The correct voltage for synchronizing and energizing is derived from the auxiliary switches of the circuit breakers, the isolator, and earthing switch and shall be selected automatically by the bay control and protection IEDs.

### 4. Transformer tap changer control

Manual raise and lower operation of OLTC taps of transformer shall be facilitated through Bay controller / Bay protection IED.

## Ethernet switch

The Ethernet Fast Switches shall be compliant to IEC 61850 and support time synchronization as per SNTP and PTP (IEEE1588 power profile). These Switches shall be suitable for the substation environment and shall conform to type tests as per IEC 61850-3. Ethernet switch shall be of 19" rack mounting type, dual power supply, 6 x FO port (100 Mbps, multimode, 1300nm, ST), 10 x copper port (10/100 Mbps, RJ45). Operating temperature range: -40 to +85 deg C.

Technical committee of the Department of Electrical Engineering **recommends for inviting technical and financial bid** for the above mentioned item to be purchased from the SAP-DRSII, UGC Project.